


DECLARATION OF CONFORMITY	No. 09QD-01ENG/V5	Date 13.06.2018	 17
<p>Product DISTRIBUTION CABLES OF RATED VOLTAGE $U_0 / U = 0.6 / 1$ kV</p> <p>Type AXPK (AXMK) 0,6 / 1 kV AXPK PLUS (AXMK PLUS) 0,6 / 1 kV AXPK PE 0,6 / 1 kV</p>			
<p>Manufacturer Prysmian Group Baltics AS Paldiski road 31, Keila 76606 Estonia</p>			
<p>Manufactured according to: HD 603 S1:1994 /A3:2007 Part 5 Section D IEC 60502-1:2009 Other requirements EN 60332-1-2:2004 /A1:2015</p>			
<p>The goods have been inspected and tested in accordance with the abovementioned technical specifications and they were found to meet all requirements stated.</p> <p>Cable is CE marked and meet the requirement of Low Voltage Directive 2014/35/EU .</p> <p>All used plastic materials are UV resistable and they don't need extra protection against sunlight.</p>			
<p>The management system of the company has found to be in conformance to ISO 9001, ISO 14001 and ISO 45001 standards</p>			
<p>Company follows and complies with the requirements of the European Commission Regulation No. 1907/2006 (REACH), likewise we will claim this from our corresponding sub suppliers.</p>			

Prysmian Group Baltics AS
Quality Department

Paavo Brauer

Paavo Brauer
Quality Manager



Note: HD 603 S1- this Harmonization Document was approved by CENELEC on 1993 - 12 - 08. CENELEC members are bound to comply with the CEN / CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document on a national level.

